



- NOTES:**
1. NO. 4 EPOXY REBAR SHALL BE INSTALLED IN ALL CURB RETURNS WITH 25' OR LARGER RADII. THE REBAR SHALL BE FROM BEGINNING TO END OF THE CURB RETURN
 2. THE TRANSITION FROM COMBINATION CURB, GUTTER AND SIDEWALK TO 6" VERTICAL CURB AND GUTTER SHALL BE OVER A MINIMUM LENGTH OF 12'.
 3. A 1' PAN MAY BE USED IN COMMERCIAL APPLICATIONS WITH THE APPROVAL OF THE TOWN ENGINEER.

VERTICAL CURB AND GUTTER DETAIL

NTS

