



6" VERTICAL CURB, GUTTER AND DETACHED WALK

NOTES

- 1. SIDEWALK WIDTH SHALL BE SPECIFIED ON THE CONSTRUCTION PLANS.
- 2. SEE DETAIL 500-01, 500-02, 500-03, 500-04 AND 500-05 FOR TYPICAL STREET CROSS SECTIONS
- 3. SIDEWALK CROSS SLOPE SHALL NOT EXCEED 2%.

VERTICAL CURB & GUTTER
DETACHED WALK
 NTS

