



- NOTES:**
1. THE SIDEWALK WIDTH SHALL BE INCREASED BY A MINIMUM OF 6" WHEREVER A HANDRAIL IS USED.
 2. IF A SIDEWALK IS MORE THAN 30" ABOVE THE ADJACENT GRADE A HANDRAIL MUST BE USED.
 3. OPEN CLEARANCE BETWEEN INTERMEDIATE RAILS MUST BE 4" OR LESS.
 4. FINISH SHALL BE EITHER GALVANIZED OR SEMI-GLOSS ENAMEL OVER A SHOP COAT OF METAL PRIMER.
 5. WHEN THE SLOPE BEHIND THE SIDEWALK IS STEEPER THAN 4:1 A HANDRAIL MUST BE USED. WHEN THE SLOPE BEHIND THE SIDEWALK IS 6:1 OR FLATTER FOR A MINIMUM DISTANCE OF 10' A HANDRAIL IS NOT REQUIRED.

PEDESTRIAN HANDRAIL DETAIL

NTS

