



NOTES:

- 1) VALVE BOX SHALL NOT BE SUPPORTED BY THE WATER LINE.
- 2) VALVE BOX TO BE PLUMB AND CENTERED OVER NUT.
- 3) VALVE BOX DETAIL SHALL APPLY TO BOTH NEW INSTALLATION & ADJUSTMENT OF EXISTING VALVES.
- 4) THE MAXIMUM DISTANCE THAT THE SCREW-IN RISER MAY EXTEND ABOVE THE TOP SECTION, WHEN INITIALLY INSTALLED, SHALL BE 1 1/2 INCHES.
- 5) WHEN ADJUSTING EXISTING VALVE BOXES, RECONNECT EXISTING TRACING WIRE IF PRESENT.

**STANDARD VALVE AND BOX DETAIL**  
NTS

