



NOTES:

- 1) IF MORE THAN ONE BARREL EXTENSION IS USED TO RAISE A FIRE HYDRANT TO GRADE, ONLY ONE STEM EXTENSION OF THE PROPER LENGTH WILL BE ALLOWED. MULTIPLE STEM EXTENSIONS ARE NOT ACCEPTABLE.
- 2) ALL METALLIC PIPE MUST BE WRAPPED IN POLYETHYLENE INCLUDING HYDRANT BARREL.
- 3) A MINIMUM OF 12 INCHES OF SLACK SHALL BE INSTALLED FOR EACH WIRE IN THE LOCATION BOX
- 4) ADDITIONAL TRACING WIRE STATIONS MAY BE NECESSARY IF FIRE HYDRANT SPACING IS TO GREAT TO ADEQUATELY TRACE THE PIPELINE.
- 5) FIRE HYDRANT LOCATIONS SHALL CONFORM TO THE INTERNATIONAL FIRE CODE.

**STANDARD FIRE HYDRANT
INSTALLATION PROFILE**

NTS

