



IF FLOOR IS CAST IN PLACE #5 REINFORCING BARS SHALL BE PLACED AT 12" O.C. BOTH WAYS.

- NOTE:
1. SHOP DRAWINGS SHALL BE SUBMITTED FOR APPROVAL.
 2. SEE DRAWINGS 700-18 FOR PLAN VIEW.
 3. NOT ALL FITTINGS AND VALVES SHOWN FOR CLARIFICATION
 4. A RECTANGULAR VAULT IS REQUIRED WHERE TELEMETRY OR ELECTRICAL EQUIPMENT INSIDE THE VAULT IS ANTICIPATED.
 5. ACCESS STAIRS WITH DOOR OUTSIDE OF PAVEMENT MAY BE REQUIRED ON STREETS WITH HEAVY TRAFFIC.
 6. SUMP PUMP AND VENT FAN REQUIRED IN VAULTS WITH ELECTRICAL OR TELEMETRY EQUIPMENT.
 7. THIS MANHOLE IS SUITABLE FOR CHECK VALVE INSTALLATIONS.
 8. THREADED FITTINGS ON LOW FLOW.
 9. COUPLING ON LOW FLOW.
 10. SADDLE FOR TAP FOR LOW FLOW
 11. ALL PIPING 4" DIAMETER OR GREATER IS D.I.P.
 12. NO PVC ALLOWED.

PRV VAULT SECTION

NTS

