



- NOTES:
1. ATTACH FABRIC TO ALL FENCE & GATE STRUCTURES AT 12" INTERVALS VERTICALLY AND AT 20" HORIZONTALLY.
  2. BRACE RAIL WILL NOT BE REQUIRED FOR 36", 42", OR 48" FABRIC HEIGHTS. BRACE RAIL FOR FENCE WITH ROLL-FORM STEEL ELEMENTS IS 12" BELOW THE TOP RAIL.
  3. CHAIN LINK SHALL CONFORM TO THE REQUIREMENTS OF AASHTO M 181.
  4. STEEL POSTS, RAILS, AND GATE FRAMES SHALL CONFORM AASHTO M 181 TYPE 1, GRADE 1 OR GRADE 2.
  5. TENSION WIRE SHALL BE CONTINUOUS BETWEEN END OR CORNER POST AND LINE BRACE POST. A TURNBUCKLE SHALL BE USED FOR EACH CONTINUOUS SPAN OF TENSION WIRE. WIRE SHALL BE AS SPECIFIED IN AASHTO M 181.
  6. CONCRETE FOOTINGS SHALL HAVE TOPS CROWNED AT GROUND LEVEL AND SHALL BE CLASS 1, AX, OR B. CONCRETE WITH LIGHTWEIGHT AGGREGATE CONFORMING TO AASHTO M 195, WILL BE PERMITTED.
  7. CHAIN LINK FABRIC UP TO 5'-0" HIGH SHALL BE KNUCKLED AT THE TOP AND BOTTOM SELVAGES. FABRIC OVER 5'-0" HIGH SHALL BE TWISTED AND BARBED ON THE TOP SELVAGE AND KNUCKLED ON THE BOTTOM SELVAGE.
  8. FENCE SHALL BE CONSTRUCTED WITH EITHER ROUND PIPE OR ROLL-FORMED STEEL COMPONENTS. THE CONTRACTOR SHALL STATE THE TYPE OF CONSTRUCTION AND TYPE OF LINE POST TO BE USED THROUGHOUT THE PROJECT ON THE CONSTRUCTION PLANS.

# CHAIN LINK FENCE DETAIL

NTS



TOWN OF FREDERICK  
STANDARDS & SPECIFICATIONS

1100-01